

TUV SUD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFIKAT ◆ 認證證書 ◆ CERTIFICATE ◆ CERTIFICATE



Product Service

# CERTIFICATE

No. Z10 040066 0003 Rev. 02

**Holder of Certificate:** E. Dold & Söhne KG  
 Bregstr. 18  
 78120 Furtwangen  
 GERMANY

**Factory(ies):** 040066



**Product:** Safety components  
 Safety Relay Emergency Stop Module

**Model(s):** BH 5928, BI 5928, LG 5928

**Parameters:**

Safety Parameter: w/o off-delay:  
 Cat 4, PL e (EN ISO 13849-1)  
 SIL 3 (EN 61508, EN 61511)  
 SILCL 3 (EN 62061)  
 with off-delay:  
 Cat 3, PL d (EN ISO 13849-1)  
 SIL 2 (EN 61508, EN 61511)  
 SILCL 2 (EN 62061)

Power Supply:  
 24 VDC (BH 5928, BI 5928, LG 5928)  
 24 V AC/DC (BH 5928, BI 5928, LG 5928)

**Tested according to:** 2006/42/EC  
 EN ISO 13849-1:2015  
 EN 62061:2015  
 EN 61508-1:2010  
 EN 61508-2:2010  
 EN 61511-1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** EF793072A1  
**Valid until:** 2023-11-21

**Date,** 2018-11-22 ( Peter Weiß )

